

3 September 1953

25X1A

With reference to Proposed Modification No. 3 covering caption change, please be advised of the following clarification of the detail as shown on the accompanying drawing, No. C-3:

The electrical service line is to be located in the same trench with the water pipe, at a minimum depth of 2'-0" below grade.

Very truly yours,


Contracting Officer

25X1A9a

CLM/jg (3 September 1953)
cc: Orig. & 1 - Courtesy
RE - Official File Copy
RE - Chrono

25X1A9a 